

# Laminex New Zealand Products

## Fire Test Classifications

Cone Calorimeter test in accordance with ISO5660 and New Zealand Building Code Verification Method C/VM2 Appendix A.

The tests were carried out and data recorded according to the test procedure described in ISO 5660: (2002), Reaction-to-fire tests - Heat release, smoke production and mass loss - Part 1: Heat release rate, and Part 2: Smoke production rate.

Product	Group Classification	Fire Test Report
Caesarstone	3	<a href="#">7-598186-CV</a>
Formica ARtouch laminate	3	<a href="#">16-006323</a>
Formica ColorCore	3	<a href="#">7-593915-CV</a>
Formica / Laminex HPL on Lakepine MDF	3	<a href="#">7-598418-CV</a>
Formica / Laminex Metallic laminate on Lakepine MDF	3	<a href="#">7-598423-CV</a>
Lakepine MDF	3	<a href="#">7-590424-CV</a>
Laminam	1	<a href="#">FH 5190</a>
Laminex Aquapanel	3	<a href="#">FH 5028</a>
Laminex Compact laminate	3	<a href="#">7-598692-CV</a>
Laminex Solid Surface	3	<a href="#">7-598-753-CV</a>
Laminex Structural board	3	<a href="#">15-000776</a>
Laminex Timber Veneer - FDTV on MDF	3	<a href="#">16-003205</a>
Laminex Timber Veneer - FNTV on MDF	3	<a href="#">16-003199</a>
Melteca	3	<a href="#">FH 5026</a>
Melteca FR	1S	<a href="#">FH 5030</a>
Melteca Clipwall Standard	3	<a href="#">EP 151868</a>
Melteca Clipwall FR Grade	2S	<a href="#">EP 151868</a>
Purecoat by Melteca	3	<a href="#">16-004835</a>
Seratone Escape	3	<a href="#">FH 5027</a>
Seratone Life	3	<a href="#">7-595506-CV</a>
Standard Hardboard	3	<a href="#">7-590420-CV</a>
Strandboard	3	<a href="#">FH 5119</a>
Strandfloor	3	<a href="#">FH 5119</a>
Superfine particleboard	3	<a href="#">7-590428-CV</a>
Tempered Hardboard	3	<a href="#">7-590426-CV</a>
Triboard	3	<a href="#">FH 5119</a>